

# VASTAVUSDEKLARATSIOON

Toote nimetus: KUULKRAAN „MISTRAL“ TIEMME SEERIA 2360-2380

Tootja nimi ja aadress: Tiemme Raccorderie S.p.A- via Cavallera 6/A

Deklaratsiooni esitaja: Onninen AS (Betooni 6, 11415 Tallinn), kes on tootja volitatud esindaja Eestis

Vastavus nõuetele: Käesoleva vastavusdeklaratsiooniga tõendab Onninen AS, et Tiemme Raccorderie S.p.A poolt valmistatavad ülalloodud tooted on kooskõlas standarditega EN 12164 ja EN 12165. Valmistatud materjalist CW617N (messing). Toode sobib joogiveele vastavalt standardiga EN 13828

Alusdokumendid: Tiemme Raccorderie S.p.A poolt väljastatud sertifikaat DC-03, Rif. UNI CEI EN 17050

Deklaratsiooni väljaandja esindaja:



Kuuno Kirspuu  
Müügidirektor, juhatuse liige

Välja antud: 30.07.2015 Tallinnas

Herewith the company **TIEMME RACCORDERIE S.P.A.**, manufacturer of fittings systems , manifolds, pipes, valves and taps for hydro-thermo-hydraulic and gas plants  
In conformity with the regulations in force,

DECLARES on their own responsibility that the following products:

## **BALL VALVES "MISTRAL"** **RANGE 2360...2380**

**MADE IN ITALY**

are produced properly following steps as below:

HOT PRESSED and MANUFACTURED at our plant in Lumezzane (BS-Italy) in accordance with an ISO 9001:2008 KIWA, certified quality procedure;

- the raw material used is brass (CW617N) in conformity with the EN 12164 and EN12165 and also is therefore suitable for contact with drinking water in conformity to EN 13828;
- the threads meet the requirements of ISO 228;
- the rings are in P.T.F.E.;
- which are adapted for employment with oil products: diesel, fuel, kerosene and not corrosive mineral oils
- the seal on the stem is guaranteed thanks to the O-ring in NBR;
- the valves have been tested and certified by the following external Certification Boards:

|   | Board / Lab.         | Country    | Product tested/certified   |
|---|----------------------|------------|--|
|  | <b>IG</b>            | Italy      | Ball valves "MISTRAL" Range 2360 – 2380 mechanic and hydraulic tests |
|  | <b>INSTAL</b>        | Poland     | Ball valves "MISTRAL" Range 2360-2380                                |
|  | <b>PZH</b>           | Poland     | Ball valves "MISTRAL" Range 2360 – 2380 sanitari test                |
|  | <b>VUPS</b>          | Czech Rep. | Ball valves "MISTRAL" Range 2360-2380                                |
|  | <b>PCT</b>           | Russia     | Ball valves "MISTRAL" Range 2360-2380                                |
|  | <b>TSUS</b>          | Slovakia   | Ball valves "MISTRAL" Range 2360-2380                                |
|  | <b>TYSK</b>          | Ukraine    | Ball valves "MISTRAL" Range 2360-2380                                |
|  | <b>EMI</b>           | Hungary    | Ball valves "MISTRAL" Range 2360-2380                                |
|  | <b>TÜV Rheinland</b> | Bulgaria   | Ball valves "MISTRAL" Range 2360-2380                                |

➔ for TSU (Slovakia) report number **S03/07/0025/4201/SC**

➔ For TUV Rheinland (Bulgaria) certificate number **018 – HCHOCCII - 003**

The Quality Control System of Tiemme Raccorderie S.p.a is certified in accordance with the rule ISO 9001:2008 KIWA (Certificate Nr. **KI-052300**). The company may provide to clients reports, tests and technical information relative to any of the above-mentioned products and when requested, may, put their knowledge at the service of the client to ensure the correct use of their products;

### DECLINES

liability for any accidents to persons or objects resulting from tampering or from uncorrect/unsuitable use installation of products.

The Technical Director  
(*electronic signature – original available at Tiemme*)