

Õhuhulgad

TABEL 1

ÕHUHULGAD

<i>Nº</i>	<i>Nimetus</i>	<i>Pind m²</i>	<i>S l/s</i>	<i>V l/s</i>	<i>Norm. müra tase dB(A)</i>	<i>Süsteem</i>	<i>Märkus</i>
	1.KORRUS						
1.1	Iluteenused	15,7	40	40	35	SV-1	+/-2,5 l/s m ²
1.2	Iluteenused	16,6	40	40	35	SV-1	+/-2,5 l/s m ²
1.3	Iluteenused	16,0	40	40	35	SV-1	+/-2,5 l/s m ²
1.4	Abiruum	19,7	20	20	35	SV-1	+/-1 l/s m ²
1.5	Koridor	21,8	70	s	35	SV-1	+bilansile
1.6	WC (1 üh)	1,3	s	20	35	SV-1	-20 l/s üh
1.7	Olmeruum	2,7	s	s			
1.8	WC (1 üh)	1,2	s	20	35	SV-1	-20 l/s üh
1.9	Personali olmeruum	1,3	s	10	35	SV-1	-10 l/s
1.10	WC (1 üh)	1,2	s	20	35	SV-1	-20 l/s üh
1.11	Olmeruum	3,5	s	s			
	KOKKU 1.korr		210	210			
	2.KORRUS						
2.1	Kabinet	15,6	20	20	35	SV-1	+/-10 l/s in
2.2	Kabinet	15,6	20	20	35	SV-1	+/-10 l/s in
2.3	Puhkeruum	13,3	40	40	35	SV-1	+/-3 l/s m ²
2.4	Kabinet (2 in)	12,0	20	23	35	SV-1	+/-10 l/s in; +bilansile
2.5	Kabinet (2 in)	16,9	20	s	35	SV-1	+10 l/s in
2.6	WC (1 üh)	2,9	s	20	35	SV-1	-20 l/s üh
2.7	Abiruum	2,9	s	3	35	SV-1	-1 l/s m ²
2.8	WC	1,9	s	20	35	SV-1	-20 l/s üh
2.9	Koridor	25,0	20	s	35	SV-1	+bilansile
2.10	Ventkamber	8,5	4	4	35	SV-1	+/-0,5 l/s m ²
	KOKKU 2.korr		150	150			
	KOKKU		360	360			

s siirdõhk