




# OU 0478 110 KV ELECTRICITY L006A/L005 TOWER TABLE



*The sole responsibility of this publication lies with the author.  
The European Union is not responsible for any use that may be made of the information contained therein.*

<div>LEPING Nr. / CONTRACT No. 2023-K063 PROJEKTI Nr. / PROJECT No. RBDTDEEDS2DPS1</div> <div></div> <div>KUJUNDUSE NIMI / DESIGN NAME</div> <div>Elingi Järveküla piirkonna õhuliinide L006A/L005, L100B/L182 RB raudteega ristumiste ümberehitus</div> <div>Reconstruction of crossings of overhead lines L006A/L005, L100B/L182 in Eling's Järveküla area with the RB railway</div> <div>ARHIIV Nr. / ARCHIVE No. 10630</div>	TELLIJA / CLIENT	TÖÖVÕTJA / CONTRACTOR	DATA / DATE	07.11.23	DOKUMENDI NIMI / DOCUMENT NAME  L005/L006A MASTITABEL / L005/L006A TOWER TABLE										
	  RAIL BALTIC ESTONIA OÜ Veskiposti 2/1 10138 Tallinn +372 6256342 www.rbestonia.ee Register code: 12734109	 LEONHARD WEISS  LEONHARD WEISS OÜ Vesse 8, 11415 Tallinn +372 601 2285 www.leonhard-weiss.ee Register code: 12083348	DOKUMENDI STATUS / DOCUMENT STATUS  ESITATUD KINNITAMISEKS / ISSUED FOR APPROVAL												
			KUTSE. / QUALIF.	NIMI / NAME	ALLKIRI / SIGN.	PROJEKTI KOOD / PROJECT CODE			ASUKOHT / LOCATION			DISTSIPLIINI KOOD / DISCIPLINE CODE		EST / ENG	
			KOOSTAJA ORIGINATOR	M.Kapanen		PROJEKT ID PROJECT ID	LÕIGU ID SECTION ID	ALALOIGU ID SUB-SECT. ID	OSA SÜSTEEM VOL. SYST.	TSOON ZONE	ASUKOHT LOCATION	RBR KOOD RBR CODE	KOHALIK KOOD LOCAL CODE	PROJEKTI ETAPP PROJECT STAGE	
			Dilpomeeritud elektriinsener, tase 7 Dilpoiam Electrical Engineer, level 7												
			KONTROLLUA CHECKER	R.Kivistik											
			Dilpomeeritud elektriinsener, tase 7 Dilpoiam Electrical Engineer, level 7												
			ULEVAATAJA REVIEWER			RBDTD-EE	DS2	DPS1	OU0478	ZZ	0009	HV	ELK	TP / DTD	
						DOKUMENDI KOOD / DOCUMENT CODE							LEHEKÜLG / PAGE	LEHED / PAGES	REVISIOON REVISION
						RBDTD-EE-DS2-DPS1_LWE_OU0478-ZZ_0009_RP_HV-ELK_DTD_801001_Tower-Table.docx							1	2	001

## MASTITABEL L006A/L005 / TOWER TABLE L006A/L005

Masti number // New Tower Number	Masti tüüp // Tower Type	Masti kõrgus 110 kV // Tower Height 110 kV	Nurk Angle (deg)	Visang Span	Piketaaž Distance	Koordinaadid // Coordinates			Vundamendi kõrgus // Height of the Foundation	Märkused/ Ristumised // Remarks/Intersections
						koordinaadid L-EST 97, kõrgused EH2000 // Coordinates L-EST 97, altitude EH2000				
N°		m		m	km+m	X	Y	Z	m	
L006A/L005_nr_65	U110-2+9	33.600	-0.1552	177	2+511	548693,44	6581823,17	49,51		
L006A/L005_nr_64	PB110-4	22.700		238	2+749	548916,533	6581905,642	51,143		
L006A/L005_nr_63	PB110-4	22.700		192	2+941	549096,758	6581972,266	51,51		
L006A/L005_nr_62	PB110-4	22.700		214	3+155	549297,18	6582046,357	49,963		
L006A/L005_nr_61	PB110-4	22.700		166	3+321	549452,972	6582103,949	49,808		
L006A/L005_nr_60	PB110-4	22.700		225	3+546	549663,65	6582181,831	51,207		
L006A/L005_nr_59	PB110-4	22.700		256	3+802	549904,092	6582270,717	51,109		
L006A/L005_nr_58	PB110-4	22.700		234	4+036	550123,643	6582351,879	50,142		
L006A/L005_nr_57	PB110-4	22.700		218	4+254	550328,5	6582427,609	47,378		
L006A/L005_nr_56	PB110-4	22.700		202	4+456	550518,312	6582497,778	45,831		
L006A/L005_nr_55Y_UUS	11T9T-19	34.000		210	4+666	550715,563	6582570,696	44,935	0,5	11113 Assaku-Jüri tee, planeeritav tee
L006A/L005_nr_54Y_UUS	11T9T-19	34.000	-18.4861	173	4+839	550877,573	6582630,587	44,01	0,5	
L006A/L005_nr_53Y_UUS	11T9T-24	39.000	52.5105	246	5+085	551069,334	6582784,624	39,9	0,5	Rail Baltica raudtee, planeeritav tee
L006A/L005_nr_52Y_UUS	11T9T-19	34.000	-37.0705	128	5+213	551193,484	6582754,276	40,87	0,5	
L006A/L005_nr_51	PB110-4	22.700		271	5+484	551442,133	6582861,537	39,475		
L006A/L005_nr_50	PB110-4	22.700		244	5+728	551666,169	6582958,181	37,912		
L006A/L005_nr_49	PB110-4	22.700		204	5+932	551853,695	6583039,075	37,666		
L006A/L005_nr_48	U110-2+5	29.700		280	6+212	552110,454	6583149,835	36,897		
L006A/L005_nr_47	U110-2+5	29.700		193	6+405	552287,79	6583226,333	36,759		
L006A/L005_nr_46	PB110-4	22.700		260	6+665	552526,765	6583329,42	35,843		
L006A/L005_nr_45	U110-2	24.700		219	6+884	552727,539	6583416,03	35,92		