



SPECIFICATION		10T2-h			
		26	23	16	11
PARTS TURVATIKAS/ SAFERAIL		PCS			
RELEASABLE VERTICAL CARRIAGE STOPPER NO 85/ MM 312		1	1	1	1
VERTICAL CARRIAGE STOPPER NO 851/ MM 311		2	2	2	2
CARRIAGE STOPPER NO 89/ MM 313		1	1	1	1
CARRIAGE GUIDE NO 84/ MM 301		3	3	3	3
UNIVERSAL FASTENER	NO 21 / MM 222 ●	7	7	7	7
ANGLE IRON FASTENER NO 34/ MM 241		16	15	10	6
SLEEVE JOINT NO 70/ MM201		9	8	6	4
CLEAT LADDER TBA-I/ MM 111, TOTAL		11	10	8	6
TOP	CLEAT LADDER TBA-I/ MM 111, L=3,0m	3	3	3	3
BODY	CLEAT LADDER TBA-I/ MM111, L=3,0m	7	7	4	2
	CLEAT LADDER TBA-I/ MM111, L=2,4m	1	-	-	1
	CLEAT LADDER TBA-I/ MM111, L=1,8 m	-	-	1	-

Remarks:

- Safety ladder system is installed from top to bottom.
- The maximum distance between two topmost fasteners is 1,0 meter.
- The recommended mounting distance for other fasteners is 1,8 metres, with the maximum allowable mounting distance being 2,1 metres.
- The maximum allowable overhang from last fastener is 1,0 meter.
- Vertical carriage stopper NO 85/MM 311, installed to lower end of ladder, must be always used with carriage guide NO 84/MM 301.
- Releasable vertical carriage stopper NO 851/MM 312, installed to upper end of ladder, must be always used with carriage guide NO 84/MM 301.
- Lowest safety ladder is cut to suitable length so sleeve joint holes at upper end are retained.
- When the fasteners are supplied with one pair of nuts, then nuts are to be locked by breaking the thread.
- For additional instructions please refer to Turvatikas/Saferail installation manual.
- In case of wide foundation (ladder can be supported on foundation) ground clearance measurement should be taken from top of foundation.

Muudatus	Kuupäev	Muudatuse sisu	Projekteeris		Kontrollis
					
			Projekteeris/Kuupäev K.Perillus/04.04.2024		
Objekt			Kontrollis/kuupäev		
110 kV õhuliini L086 üksikute mastide vahetus			J.Karin/04.04.2024		
Joonise nimi			Kooskõlastas		
			Joonestas		
Metallsõrestik nurga-ankrumasti 10T2 turvaredel					
Projekti number	Stadium	Joonise number	Muudatus	Leht	Lehti
KPL2310K1	TP	EL2-7-01-004	----		
				Mõõtkava	Formaat
				1:150	A3