



CERTIFICATE OF CONSTANCY OF PERFORMANCE
2268-CPR-234

Notified body No. 2268

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

External fire resisting and smoke control pedestrian doorset
(product)

Single leaf "FD-EI60" and double leaf "FDD-EI60" external hinged glazed doorset
(see annex 1)
(product type and parameters)

produced by the manufacturer

"OLGALEK" SIA

Juglas 14A, Riga, LV-1024 Latvia/company code: 40003611779
(name and address of the manufacturer, company code)

in the manufacturing plant
Juglas 14A, Riga, LV-1024 Latvia
(address of the manufacturing plant)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 16034:2014 * (shall only be applied together with EN 14351-1:2006+A2:2016*)

under system 1 are applied and that the products and the factory production control fulfils all the prescribed requirements set out above.

This certificate was first issued on **2018-12-10** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product and the factory production control itself are not modified significantly.

The certificate issued on 2021-10-08.

Mindaugas Grigonis
Certification business unit manager

* - this standard is adopted as Lithuanian national standard.

UAB „Kiwa Inspecta“
Ukmergės g. 308,
LT-12110 Vilnius, Lietuva
Tel. +370 5 2031395
Fax. +370 5 2031396
lithuania@kiwa.com
www.kiwa.lt



LIETUVOS
NACIONALINIS
AKREDITACIJOS
BIURAS

PRODUKTU SERTIFIKAVIMAS
ISOTEC 17065

Nr. LA.03.013



CERTIFICATE OF CONSTANCY OF PERFORMANCE

2268-CPR-234

Annex 1

Product: Single leaf "FD-EI60" and double leaf "FDD-EI60" external hinged glazed doorset Intended use: fire and/or smoke compartmentation and/or escape routes			
Essential Characteristics	European Standards(s) related to essential characteristics	Performance ¹⁾	Notes
Resistance to fire	EN 1634-1 EN 13501-2	E 60, EI ₂ 60, EW 60	class
Smoke control	EN 1634-3 EN 13501-2	S _a S ₂₀₀	class
Ability to release	EN 16034, clause 4.3	released	
Self-closing	EN 13501-2 EN 16034	C	class
Durability of ability to release	EN 16034, clause 4.5.1	release maintained	
Durability of self-closing – against degradation (cycling testing)*	EN 1191 EN 16034	200 000 5	cycles class
Durability of self-closing – against ageing (corrosion)	EN 16034, clause 4.5.2.2	NPD ²⁾	
¹⁾ the scope of products covered by this certificate can be found in the extended application report No. 04-451-18-01-rev-2 (2021-10-08) and classification report No. 04-451-18-01-rev-2 (2021-10-08); ²⁾ NPD – No Performance Determined.			

Mindaugas Grigonis
Certification business unit manager
2021-10-08