

188 — 189 — 190

10,5/0,41 kV
160 kVA
Y/Yn-0




LKR-189B

200/400A
F1

Olemasolev
Projekteeritud
Planeeritud
Ei kuulu projekti mahtu

$I_k=1400A$
 $\Delta U=3,7\%$


LK-F2
(vundamendil)



AXPK 4G150

L=3m+183m+3m

LK-F1
(vundamendil)



AXPK 4G150

L=3m+42m+3m

Elektrilevi OÜ
liitumiskilp



Swiper OÜ
reg.nr: 14690110
+372 5386 6932
KMKR: 102331428
TEL003489
info@swiper.ee

Kontrollis	Artur Vilu	20.12.2025
Projekteeris	Artur Vilu	20.12.2025

Faili nimi
SW251105_TP_EL-5-01_elektriskeem.dwg

Tellija AS Eesti Raudtee		Projekti nr. SW251105	
Töö nimi CCS rajatiste elektrivarustus 2025. Vaeküla CCS moodulhoone elektrivarustus. Vaeküla raudteejaam, Mõedaka küla, Vinni vald, Lääne-Viru maakond		Joonise nr. EL-5-01	Versioon. 01
		Stadium TP	Leht 1/1
Joonise nimi Elektriskeem		Suurus A4	Mõõtkaava