



VĮ STATYBOS PRODUKCIJOS CERTIFIKAVIMO CENTRAS
Linkmenų str. 28, LT-08217 Vilnius, Lithuania
Notified body No. 1397



BANDYMAI
ISO/IEC 17025

LIETUVOS
NACIONALINIS
AKREDITACIJOS
BIURAS

Nr. LA. 01.103

Waste water treatment plant laboratory

TEST REPORT No. 1397-CPR-155/A.2
EN 12566-3:2005+A2:2013 Annex A.2, watertightness

2016-05-16

1. CLIENT: Novewater OÜ, reg. Nr.12171528, Suur – Sõjamäe 27c, Tallinn 11415, Estonia, contract No. NVI-87_2016 at 2016-03-30.
2. MANUFACTURER: Novewater OÜ, reg. Nr.12171528, Suur – Sõjamäe 27c, Tallinn 11415, Estonia.
3. SAMPLE: Small wastewater treatment system (SWWTS) ST4. Material – Glass reinforced plastic (GRP).
4. SAMPLE DELIVERY DATE: 2016-03-29.
5. TESTING LOCATION, ADDRESS AND DATE:
 - Wastewater treatment plant laboratory Maišiagala, Vilnius district;
 - The date 2016-04-06.
6. SAMPLING: Sampling was made by the Client. Sampling report No. 081- Novewater.
7. THE TEST MADE ACCORDING TO:
EN 12566-3:2005+A2:2013 *Small wastewater treatment systems for up to 50 PT — Part 3: Packaged and/or site assembled domestic wastewater treatment plants*, item 6.4.2 and Annex A, item A.2.
8. TEST SPECIFICATIONS:
Plant was filled with pure water up to the top of the plant, for 30 min.
9. TEST RESULTS: There was no leakage from the SWWTS. The SWWTS is watertight.
10. ASSESSMENT: The SWWTS is watertight.
11. OTHER INFORMATION: -
12. ANNEXES: -

This test report only certifies the characteristics of the sample submitted for testing.

Head of laboratory

Arnas Danila

Director

Robertas Encius

