

STATEMENT

We,

FAKRO PP Sp. z o.o.
ul. Węgierska 144 a
33-300 Nowy Sącz, Poland

hereby declare that **FAKRO FSR P5** natural smoke and heat exhaust ventilator is compliant with the requirements of EN 12101-2:2003 standard.

Additional thermal transmittance test have been carried out by Laboratorium Techniki Budowlanej in Dąbrowa Górnicza - test report No. 226/B-2019 of 21/05/2019.

$U_w=0,94$ [W/m²K]*

** result is given for window size 114x140 (calculation according to standard EN ISO 10077-1).*

For **FSR P5** natural smoke and heat exhaust ventilator (marked with CE in accordance with harmonized standard EN 12101-2:2003) was issued the *Declaration of Performance* No. RS41/CPR/12101/xx**.

** - year of issue Declaration of Performance

Nowy Sącz, 06/05/2022

 **FAKRO[®] PP Sp. z o.o.** -1-
33-300 Nowy Sącz ul. Węgierska 144a
tel: (018) 444 0 444 fax (018) 444 0 333
NIP 734-28-87-530 REGON 492727063
BDO 000029378


Ewa Łukaszczyk-Haslik
Dyrektor ds. Certyfikacji i Kontroli Jakości