

IP00 TRANSFORMER ASSEMBLY

TERMINALS AT TOP OF TRANSFORMER

CENTRALIZATION AUXILIARY BOX

PT100 AT TOP OF THE CORE

IF REQUIRE

PT100

WHITE

RED

RED

T-154

CH1


CH2

CH3


CH4

ALARM TRIP FAULT FAN

24-240 Vac-dc
50-60Hz - 3VA



ISO 128 PRO. ORT. EUR.



Emitted	Martini	Scale	---
Appr./Control.	Galasso	Size	A4
Date	---	MATR.	---
Custom	---	TYPE	---
NAME DRAWING	Schema posizionamento sonda PT100	COD. REG.	---
FILE	Schema pos sondaPT100.dwg		