


The drawing shows a cable route plan with the following details:

- Segment 1 (Left):** Mesilinnu tee 1 (25501:001:0456). The route starts at an elevation of approximately 93.5m and crosses the road at 94.3m. A label "maapind" (ground surface) is present.
- Segment 2 (Middle):** Koeru-Visusti jälgtee L3 (25501:001:0849). The route continues from the first segment, crossing the road at 94.3m. A label "maapind" is present. The route then crosses the road at 94.3m and continues to the right.
- Segment 3 (Right):** Jaani tee 20 (31401:002:2100). The route starts at an elevation of approximately 93.5m and crosses the road at 94.3m. A label "maapind" is present. The route then crosses the road at 94.3m and continues to the right.
- Other Labels:** "Kü piir" (boundary), "tee teig" (road right-of-way), "sõidutee" (road), "kaevik" (ditch), "Proj. 0,4kV maakaabel" (0.4kV cable), "Olemasolev sidekaabel" (existing side cable), "Puurimise pikkus 12,7m" (excavation length 12.7m), "1,0m", "2,2m", "0,4m", "1,3m", "W1".

Projekt:	Järvamaa, Järva vald, Koeru alevik 15114 Koeru-Visusti teel võrgu ümberehitus					Tellija:	Elektrilevi OÜ		
						Töö nr:	TC0131		
Joonis:	Pikiprofiil - Lõige 1					Joonise nr:	TC0131-2		
<div> <b>CONNECTO</b></div>	AS Connecto Eesti Registrikood: 10722319 Tuisu tn 19, 11314 Tallinn tel. 606 3100 info@connecto.ee www.connecto.ee		Projekteeris	Erki Pääro					
			Kontrollis	Jako Kruusement					
				Mõõtkava:	-		Leht	Lehti	
				Staadium:	TP		1	1	