




TAKEN FROM EVR
SCADA VISUALIZATION
MUST BE RE-DEFINED?

PRELIMINARY VERSION!

TA6	14.08.2025	EVR COMMENTS CORRECTED	JFA	
TA5	01.08.2025	ESTONIAN IDENTIF. SYSTEM & MT'S ACCUR. UPDATED	JFA	
TA4	19.05.2025	CABLE SHIELD EARTHINGS UPDATED	JFA	
TA3	06.05.2025	CT'S ADDED TO TRAF0 N1/N2 BUSHINGS	JFA	
TA2	18.02.2025	Panel 05 / 06 / 07 CHANGES	JFA	
TA1	07.01.2025	FIRST VERSION	JFA	
Revision	Date	Revision note	Designed	Checked
<div><div> EESTI RAUDTEE</div><div> GRK</div><div> DESPRO</div></div>				
Date	7.1.2025	Title	TSS4 ORU 110/2x25 kV SUBSTATION MAIN DIAGRAM	
Designed	JFA	Filename	140004_TSS4_EL_7_300.dwg	
Checked/Approved	PKI/	Scale		Paper size A1
Replaces		Drawing number	140004_TSS4_EL_7_300	
		Version	TA6	Sheet 2/2

TA2 18.2.2025 - T2 INCOMER PLACE MOVED NEXT TO THE PANEL 04
- Panel 06 & 07 CHANGED VICE VERSA
- DISCONENCTOR P ADDED