

Proovi võtmise koht	Pa 1	Pa 1	Pa 2	Pa 2	Pa 3	Pa 3	Pa 4	Pa 4	Pa 5	Pa 5	Pa 6	Pa 6	Pa 7	Pa 7	Pa 8	Pa 8	Pa 9	Pa 9	Pa 10	Pa 10	Pa 11
Proovi nr	1-1	1-2	2-1	2-2	3-1	3-2	4-1	4-2	5-1	5-2	6-1	6-2	7-1	7-2	8-1	8-2	9-1	9-2	10-1	10-2	11-1
Proovimise intervall, m	0,4-2,0	2,0-3,7	0,3-2,0	2,0-3,6	0,4-2,5	2,5-3,5	0,5-3,5	3,5-5,5	0,3-2,5	2,5-5,0	0,3-3,4	3,4-8,0	0,3-1,5	1,5-4,3	0,5-2,0	2,0-4,3	0,3-2,0	2,0-4,7	0,3-2,5	2,5-4,0	0,4-3,0
Proovi pikkus, m	1.6	1.7	1.7	1.6	2.1	1.0	3.0	2.0	2.2	2.5	3.1	4.6	1.2	2.8	1.5	2.3	1.7	2.7	2.2	1.5	2.6
Fraktsioonid, mm	Jääk sõelal massi%-des																				
>80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
80...63	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
63...40	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
40...31,5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0
31,5...20	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	2.0	0.0	2.0	0.0	2.0	0.0	1.0	0.0	3.0	0.0	2.0	1.0
20...16	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	1.0	0.0	4.0	0.0	3.0	0.0	1.0	0.0	2.0	1.0	1.0	2.0
16...12,5	0.0	0.0	0.0	0.0	0.0	1.0	1.0	1.0	0.0	1.0	1.0	5.0	1.0	5.0	0.0	2.0	0.0	3.0	1.0	1.0	3.0
12,5...8.0	1.0	1.0	0.0	1.0	0.0	1.0	2.0	0.0	0.0	4.0	1.0	9.0	1.0	9.0	1.0	4.0	0.0	4.0	2.0	2.0	8.0
8,0...6,3	0.0	0.0	1.0	1.0	0.0	0.0	1.0	1.0	0.0	2.0	1.0	4.0	1.0	4.0	1.0	3.0	0.0	2.0	2.0	1.0	4.0
6,3...4,0	0.0	2.0	2.0	3.0	1.0	2.0	2.0	1.0	2.0	6.0	2.0	8.0	2.0	7.0	2.0	6.0	1.0	5.0	4.0	4.0	5.0
4,0...2,0	1.0	1.0	3.0	4.0	0.0	3.0	2.0	1.0	4.0	6.0	2.0	6.0	3.0	6.0	4.0	5.0	1.0	5.0	4.0	3.0	5.0
2,0...1,0	3.0	4.0	4.0	5.0	4.0	3.0	7.0	3.0	5.0	10.0	5.0	11.0	7.0	6.0	12.0	8.0	15.0	8.0	11.0	4.0	6.0
1,0...0,5	15.0	14.0	12.0	10.0	16.0	8.0	17.0	9.0	16.0	13.0	15.0	14.0	16.0	9.0	23.0	12.0	26.0	12.0	22.0	8.0	9.0
0,5...0,25	60.0	53.0	58.0	42.0	53.0	39.0	44.0	25.0	48.0	27.0	49.0	18.0	49.0	24.0	37.0	31.0	42.0	32.0	36.0	38.0	23.0
0,25...0,125	17.0	22.0	17.0	30.0	23.0	37.0	16.0	41.0	20.0	24.0	20.0	11.0	15.0	12.0	13.0	22.0	10.0	18.0	13.0	31.0	26.0
0,125...0,063	1.0	0.7	1.0	1.1	0.6	1.7	1.6	12.0	1.2	1.4	1.1	1.5	1.1	1.8	1.3	1.5	1.7	1.4	0.9	1.0	2.8
>31,5 mm	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	0.0
Savi ja tolmu sisaldus (<0,063 mm)	2.0	2.3	2.0	2.9	2.4	4.3	4.4	6.0	3.8	2.6	2.9	6.5	3.9	11.2	5.7	3.5	3.3	3.6	3.1	4.0	5.2
Liiva sisaldus (0,063...2,0 mm)	96.0	93.7	92.0	88.1	96.6	88.7	85.6	90.0	90.2	75.4	90.1	55.5	88.1	52.8	86.3	74.5	94.7	71.4	82.9	82.0	66.8
Kruusa sisaldus (2,0...20 mm)	2.0	4.0	6.0	9.0	1.0	7.0	9.0	4.0	6.0	20.0	7.0	36.0	8.0	34.0	8.0	21.0	2.0	21.0	14.0	12.0	27.0
>20 mm	0.0	0.0	0.0	0.0	0.0	0.0	1.0	0.0	0.0	2.0	0.0	2.0	0.0	2.0	0.0	1.0	0.0	4.0	0.0	2.0	1.0
Sõela ava, mm	Läbis sõela massi%-des																				
125	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
80	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
63	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
40	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
31.5	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0	99.0	100.0	100.0	100.0
20	100.0	100.0	100.0	100.0	100.0	100.0	99.0	100.0	100.0	98.0	100.0	98.0	100.0	98.0	100.0	99.0	100.0	96.0	100.0	98.0	99.0
16	100.0	100.0	100.0	100.0	100.0	100.0	98.0	100.0	100.0	97.0	100.0	94.0	100.0	95.0	100.0	98.0	100.0	94.0	99.0	97.0	97.0
12.5	100.0	100.0	100.0	100.0	100.0	99.0	97.0	99.0	100.0	96.0	99.0	89.0	99.0	90.0	100.0	96.0	100.0	91.0	98.0	96.0	94.0
8	99.0	99.0	100.0	99.0	100.0	98.0	95.0	99.0	100.0	92.0	98.0	80.0	98.0	81.0	99.0	92.0	100.0	87.0	96.0	94.0	86.0
6.3	99.0	99.0	99.0	98.0	100.0	98.0	94.0	98.0	100.0	90.0	97.0	76.0	97.0	77.0	98.0	89.0	100.0	85.0	94.0	93.0	82.0
4	99.0	97.0	97.0	95.0	99.0	96.0	92.0	97.0	98.0	84.0	95.0	68.0	95.0	70.0	96.0	83.0	99.0	80.0	90.0	89.0	77.0
2	98.0	96.0	94.0	91.0	99.0	93.0	90.0	96.0	94.0	78.0	93.0	62.0	92.0	64.0	92.0	78.0	98.0	75.0	86.0	86.0	72.0
1	95.0	92.0	90.0	86.0	95.0	90.0	83.0	93.0	89.0	68.0	88.0	51.0	85.0	58.0	80.0	70.0	83.0	67.0	75.0	82.0	66.0
0.5	80.0	78.0	78.0	76.0	79.0	82.0	66.0	84.0	73.0	55.0	73.0	37.0	69.0	49.0	57.0	58.0	57.0	55.0	53.0	74.0	57.0
0.25	20.0	25.0	20.0	34.0	26.0	43.0	22.0	59.0	25.0	28.0	24.0	19.0	20.0	25.0	20.0	27.0	15.0	23.0	17.0	36.0	34.0
0.125	3.0	3.0	3.0	4.0	3.0	6.0	6.0	18.0	5.0	4.0	4.0	8.0	5.0	13.0	7.0	5.0	5.0	5.0	4.0	5.0	8.0
0.063	2.0	2.3	2.0	2.9	2.4	4.3	4.4	6.0	3.8	2.6	2.9	6.5	3.9	11.2	5.7	3.5	3.3	3.6	3.1	4.0	5.2
	Katsetused teostas: Teede Tehnokeskuse AS laboratoorium, katseprotokoll nr 1916/19																				
	Koostas: Anne Rooma, Maavarauuringud OÜ										Märkus: puuraukude koordinaadid lisas nr 2										

[illegible]

Proovi võtmise koht	Pa 5	Pa 6	Pa 7	Plokk 3	Pa 5	Pa 6	Pa 7	Plokk 4
Proovi nr	5-1	6-1	7-1	kaalutud	5-2	6-2	7-2	kaalutud
Proovimise intervall, m	0,3-2,5	0,3-3,4	0,3-1,5	keskmisena	2,5-5,0	3,4-8,0	1,5-4,3	keskmisena
Proovi pikkus, m	2.2	3.1	1.2	6.5	2.50	4.60	2.80	9.90
Fraktsioonid, mm								
>80	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
80...63	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
63...40	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
40...31,5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
31,5...20	0.0	0.0	0.0	0.0	2.0	2.0	2.0	2.0
20...16	0.0	0.0	0.0	0.0	1.0	4.0	3.0	3.0
16...12,5	0.0	1.0	1.0	0.7	1.0	5.0	5.0	4.0
12,5...8.0	0.0	1.0	1.0	0.7	4.0	9.0	9.0	7.7
8,0...6,3	0.0	1.0	1.0	0.7	2.0	4.0	4.0	3.5
6,3...4,0	2.0	2.0	2.0	2.0	6.0	8.0	7.0	7.2
4,0...2,0	4.0	2.0	3.0	2.9	6.0	6.0	6.0	6.0
2,0...1,0	5.0	5.0	7.0	5.4	10.0	11.0	6.0	9.3
1,0...0,5	16.0	15.0	16.0	15.5	13.0	14.0	9.0	12.3
0,5...0,25	48.0	49.0	49.0	48.7	27.0	18.0	24.0	22.0
0,25...0,125	20.0	20.0	15.0	19.1	24.0	11.0	12.0	14.6
0,125...0,063	1.2	1.1	1.1	1.1	1.4	1.5	1.8	1.6
>31,5 mm	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Savi ja tolmu (<0,063 mm)	3.8	2.9	3.9	3.4	2.6	6.5	11.2	6.8
Liiva (0,063...2,0 mm)	90.2	90.1	88.1	89.8	75.4	55.5	52.8	59.8
Kruusa (2,0...20 mm)	6.0	7.0	8.0	6.8	20.0	36.0	34.0	31.4
>20 mm	0.0	0.0	0.0	0.0	2.0	2.0	2.0	2.0
Sõela ava, mm								
125	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
80	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
63	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
40	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
31.5	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0
20	100.0	100.0	100.0	100.0	98.0	98.0	98.0	98.0
16	100.0	100.0	100.0	100.0	97.0	94.0	95.0	95.0
12.5	100.0	99.0	99.0	99.3	96.0	89.0	90.0	91.1
8	100.0	98.0	98.0	98.7	92.0	80.0	81.0	83.3
6.3	100.0	97.0	97.0	98.0	90.0	76.0	77.0	79.8
4	98.0	95.0	95.0	96.0	84.0	68.0	70.0	72.6
2	94.0	93.0	92.0	93.2	78.0	62.0	64.0	66.6
1	89.0	88.0	85.0	87.8	68.0	51.0	58.0	57.3
0.5	73.0	73.0	69.0	72.3	55.0	37.0	49.0	44.9
0.25	25.0	24.0	20.0	23.6	28.0	19.0	25.0	23.0
0.125	5.0	4.0	5.0	4.5	4.0	8.0	13.0	8.4
0.063	3.8	2.9	3.9	3.4	2.6	6.5	11.2	6.8
Märkus: puuraukude koordinaadid lisas nr 2 puuraukude kataloog								
Katsetused teostas: Teede Tehnokeskuse AS laboratoorium, katseprotokoll nr 1916/19								
Koostas: Anne Rooma, Maavarauuringud OÜ								