

Spetsifikatsioon Õismäe tee 105, Tallinn, Harjumaa

	Suitsueemaldus automaatika	Tüüp	Hulk	Ühik	Tarnija
1	Tuleohutuas automaatika keskseade(TOAK)	Advanced MX-5101VL	1	kompl	Atea AS
2	Aku 20 AH 12 VDC	PG12V20	2	kompl	Paradox OÜ
3	SVJK Kilp	800x1000	1	kompl	Speleta AS
4	STJK Kilp	800x1000	1	kompl	Speleta AS
5	Toiteplokk EN54 24VDC 10A	Pulsar EN54M-10A40-65	1	kompl	Walde AS
6	Aku 65 AH 12 VDC	PG12V65	2	kompl	Paradox OÜ
7	4 In/4 out moodul	ADV VMIC404	9	kompl	Atea AS
8	6 In/2 out moodul	ADV VMIC602	13	kompl	Atea AS
9	Led moodul 48 led 16 inputs	ADV MXP-539	3	kompl	Atea AS
10	Infotabloo	250x800mm	1	kompl	Speleta AS
11	Kettajam KS4 800 S12 24V L. Ketipikkus 800mm	Aumuller	27	tk	Lenmar Group
12	F41 bracket		27	tk	Lenmar Group
13	K134 bracket (väljaavanev aken)		27	tk	Lenmar Group
14	Tulekindel Harukarp	Spelberg WKE-2-5X6	30	kompl	WEG Eesti AS
15	Kaabel 4x2x0.8 FE180PH90	JE-H(st)H FE180 PH120	1500	m	Lansyst OÜ
16	Kaabel FRH 5G4		250	m	ESVIKA
17	Kaabel FRH 5G6		100	m	ESVIKA
18	Installtarvikud		1	kompl	

Koostas: Dmitri Bavõkin