



Akrediteeritud
L020

TÜV EESTI OÜ

Masina 11, 10144 Tallinn, Estonia
tel +372 60 75 918 ; fax +372 63 79 601
e-mail: info@tuev-nord.ee

Testing Laboratory:

Vana-Narva mnt. 24B, Maardu, Estonia
tel +372 63 79 306; faks +372 63 79 601
e-mail: test@tuev-nord.ee



Page 1 of 3

CLASSIFICATION OF REACTION TO FIRE in accordance with EVS-EN 13501-1:2007

SPONSOR: Novewater OÜ

ADDRESS : Suur-Sõjamäe 27C, 11415 Tallinn Estonia

MANUFACTURER: Novewater OÜ

ADDRESS : Suur-Sõjamäe 27C, 11415 Tallinn Estonia

PREPARED BY: TÜV EESTI OÜ

NOTIFIED BODY No: 1526

PRODUCT NAME : Glass reinforced plastic sheet made of composite resin and glass reinforcement layers

CLASSIFICATION REPORT : TEK- 127/14en

ISSUE NUMBER :**VÄLJA LÄINUD**
Nr. 103
2.0.05-2014.....

DATE OF ISSUE : 20.05.14

This classification report consists of three (3) pages.



1. Introduction.

This classification report in accordance with the procedures given in EVS-EN 13501-1:2007 defines the reaction to fire classification assigned to the glass reinforced plastic sheet.

2. Classified product.

2.1 General

Product is defined as a glass reinforced plastic sheet for construction of separator systems for liquids.

2.2 Description

Composite resin was applied between glass reinforcements, total of 7 layers, product total thickness range 4-9 mm. Information of used materials are detailed in testreports listed in 3.1.

3. Test reports / extended application reports and test results in support of the classification.

3.1. Test reports and extended application reports

Test Laboratory	Name of sponsor	Test report and date	Test method
TÜV Eesti OÜ	Novewater OÜ	No. 017-14TM of 15.05.2014	EN ISO 11925-2:2010 surface exposure
TÜV Eesti OÜ	Novewater OÜ	No. 018-14TM of 15.05.2014	EN ISO 11925-2:2010 surface exposure

3.2. Test results

Test method	Parameter	No. tests	Results	
			Continuous parameter	Compliance
EN ISO 11925-2:2010	Flame spread in excess of 150 mm vertically (applied to surface)	12	Did not reach	Compliant



4. Classification and field of application

4.1 Reference on classification.

This classification has been carried out in accordance with EVS-EN 13501-1:2007/A1:2009

4.2 Classification.

Product glass reinforced plastic sheet is classified to:

Fire behaviour		Smoke production		Flaming droplets	
E	-	-	-	-	-

Reaction to fire classification: E

4.3 Field of direct application.

This classification is valid for the following end use applications:

Novewater OÜ glass reinforced sheet material can be used in vertical and horizontal directions. Product thickness up to 9 mm.

5. Limitations

This classification report does not represent type approval or certification of the product.

On behalf and by authority of TÜV Eesti OÜ.

Prepared and
approved by Fred Haas

Head of the laboratory

