

From: "Laur Tarmo" <Tarmo.Laur@enersense.com>
Sent: 22/10/2024 12:54:09
To: "Edela regioon" <edela.regioon@rmk.ee>
Cc:
Subject: LC2397. Aru kinnistu elektrivarustuse tööprojekt. Levalõpme k., Muhu vald, Saare maakond

tarmo.laur@enersense.com ei saada teile sageli meilisõnumeid. [Lugege täpsemat teavet selle kohta, miks see on oluline](#)

Tere,

Saadan kooskõlastamiseks Aru kinnistu liitumisühenduse elektriprojekti.
Kas antud lahendus on Teile sobilik?

Lisainfo:

Maakaabelliini kaitsevöönd on 1 m kummalegi poole kaablit.

Vastavalt kehtivale seadusandlusele peab Elektrilevi OÜ uue elektripaigaldise (0,4 kV maakaabel, liitumiskilp, vm.) ehitamiseks sõlmima kinnistu omanikuga notariaalse maakasutuslepingu.

Notariaalse maakasutuslepingu valmistab ette ja notari lepingu sõlmimisega seotud kulud tasub Elektrilevi.

Lugupidamisega,

Tarmo Laur

Projekteerija
Enersense AS

Mobiil: +372 51 36 891

E-mail: tarmo.laur@enersense.com

Aadress: Energia 4, 80042 Pärnu, Eesti

www.enersense.ee



This e-mail and any attachments hereto are confidential and intended only for a specific individual and purpose. It may contain information which is privileged or otherwise protected against unauthorized disclosure or communication. If you are not the intended recipient, please notify (telephone or e-mail) the sender immediately and delete this message and any attachments from your system without producing, distributing or retaining copies thereof or disclosing its contents to any other person. Thank you.