





AS Inspecta Latvia Skanstes iela 54A, Rīga LV-1013, Latvija

T. +371 67 607 900 F. +371 67 607 901 latvia@kiwa.com



Certificate of constancy of performance No. 1325-CPR-3861

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product(s)

External pedestrian doorsets with fire resistance properties made of steel profile systems Stålprofil Concept SP700 manufactured by "STÅLPROFIL AB" according to the Annex

PLACED ON THE MARKET UNDER THE NAME OF:

SIA "ELAKS"

Mazā Rencēnu iela 10, Riga, LV-1073, Latvia; reg. No. 40103001451

ADDRESS OF MANUFACTURER: SIA "Elaks" factory, Mazā Rencēnu iela 10, Riga, LV-1073, Latvia

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

> EN 16034:2014 and EN 14351-1:2006+A2:2016

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 3 September 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by notified factory production control certification body.

(next surveillance - November 2023)

11 December 2022

Sertificile College Co Martins Maskavs AS Inspect Certification Manager

Certificate issued on 1 (one) page with Annex on 1 (one) page

Inspecta Latvia Trust, Quality & Progress

Annex

Certificate No. 1325-CPR-3861



Product: External pedestrian doorsets with fire resistance properties made of steel profile systems manufactured by "STÅLPROFIL" (address of manufacturer: Kärrastrandsvägen 126, SE-45176 Uddevalla, Sweden)

Manufacturer: SIA "Elaks", Mazā Rencēnu iela 10, Riga, LV-1073, Latvia

Nr.	Fire resistance E EI ₁ EI ₂ EW	Stålprofil Concept SP 700		
1.:		El ₂ 30-C/EW 30-C /E 30-C (El ₂ 30-C5/EW 30-C5/E 30-C5)	El ₂ 60-C *(El ₂ 60-C0/EW 60-C0/E 60-C0)	El₂ 90-C
2.	Smoke control	S _a /S ₂₀₀	S _a /S ₂₀₀	Sa/S200
3.	Disconnecting ability	NPD	NPD	NPD
4.	Self-closing	С	С	С
5.	Disconnecting ability resistance	NPD	NPD	NPD
6.	Self-closing resistance Cyclicality	0 (5)	5	0
	Corrosion resistence	pass	pass	pass

The external pedastrian doorsets may be modified in accordance with conditions mentioned in the Danish Institute of Fire and Security Technology (DBI) reports

PCA10207A (20.12.2019.), PHB10026 (20.12.2019.);

PCA10477A (05.03.2018.), PHB10053A (30.01.2018.);

PCA10588A (15.11.2019.), PHB10067A (11.09.2019.);

*PCA10208A (30.04.2015.), * PHB10027A (29.04.2015.) and

Research Institutes of Sweden AB (RISE) reports

3P07556-1 (01.02.2019.), 3P07556-2 (15.10.2019.) and

Technical Research Institute of Sweden (SP) report

PX14306E (15.02.2016.)

Martins Maskavs
Certification Mahager

AS Inspector



AS Inspecta Latvia Skanstes iela 54A, Rīga LV-1013, Latvija

T. +371 67 607 900 F. +371 67 607 901 latvia@kiwa.com